

KLAXON - SONOS AND NEXUS VOICE SOUNDER MESSAGES

STANDARD MESSAGE LIBRARY

ALERT

- AL1 This is a fire alert. This is a fire alert. Await further instructions. Await further instructions.
- AL2 There is an emergency. Await further instructions.
- AL3 This is a fire alarm alert. Await further instructions.
- AL4 This is a fire alarm. This is a fire alarm.
- AL5 This is an emergency alert. This is an emergency alert. Await further instructions. Await further instructions.
- AL6 This is a fire alert. Please await further instructions.
- AL7 Fire! Fire! Do not enter.
- AL8 Refuge point activation.

EVACUATE

- EV1 Fire! Fire! Please leave the building. Fire! Fire! Leave the building.
- EV2 In the interest of safety, please evacuate the building immediately.
- EV3 Fire detected. Keep calm. Leave the building by the nearest exit.
- EV4 Attention! Attention! Please leave by the nearest exit.
- EV5 Attention! Attention! This is a fire emergency. Please evacuate the building.
- EV6 In the interest of safety, please evacuate the building.
- EV7 This is a fire alarm. Please evacuate the building.
- EV8 This is a fire alarm. Please evacuate the building immediately.
- EV9 Please evacuate. There is a fire incident.
- EV10 Fire emergency. Please evacuate.
- EV11 We have an emergency situation. Please leave the building by the nearest exit immediately.
- EV12 Fire! Fire! Please evacuate the building.
- EV13 This is a fire alarm. Please evacuate the area immediately.
- EV14 This is a fire alarm! Please leave the building immediately by the nearest available exit
- EV15 This is a fire alarm. This is a fire alarm.
- EV16 Attention! Attention! This is a fire emergency. Please evacuate by the nearest exit.

ALL CLEAR

- AC1 All clear. All clear. No further action required.
- AC2 The fire alarm test is now complete.
- AC3 Alarm test is now completed.

TEST

- TE1 This is a fire alarm test. No action required. No action required.
- TE2 Fire alarm test now complete.
- TE3 Alarm test only. No action required.
- TE4 May I have your attention please. May I have your attention please. The fire system is about to be tested. Please take no further action.
- TE5 May I have your attention please. May I have your attention please. The fire alarm test is now complete. Thank you for your co-operation.

KLAXON - SONOS AND NEXUS VOICE SOUNDER MESSAGES

GAS / CHEMICAL RELEASE

- GS1 Attention, attention. 1st Stage extinguishing system alarm. Action required.
- GS2 Attention, attention. 2nd stage extinguishing system alarm. Extinguishing system release imminent. Please evacuate the area.
- GS3 Attention, attention. Extinguishing system hold-off device operated. Extinguishing system release on hold.
- GS4 Attention, attention. Extinguishing system has discharged. Do not enter.
- GS5 1st Stage extinguishing system alarm. Action required.
- GS6 2nd stage extinguishing system alarm. Extinguishing system release imminent. Please evacuate the area.
- GS7 Extinguishing system hold-off device operated. Extinguishing system release on hold.
- GS8 Extinguishing system has discharged. Do not enter.
- GS9 Attention, attention. FM200 extinguishing system 1st Stage alarm. Action required.
- GS10 Attention, attention. FM200 extinguishing system 2nd stage alarm. Extinguishing system release imminent. Please evacuate the area.
- GS11 Attention, attention. FM200 extinguishing system hold-off device operated. Extinguishing system release on hold.
- GS12 Attention, attention. FM200 extinguishing system has discharged. Do not enter. GS13 FM200 extinguishing system 1st Stage alarm. Action required.
- GS14 FM200 extinguishing system 2nd stage alarm. Extinguishing system release imminent. Please evacuate the area.
- GS15 FM200 extinguishing system hold-off device operated. Extinguishing system release on hold.
- GS16 FM200 extinguishing system has discharged. Do not enter.
- GS17 Attention, attention. Novec extinguishing system 1st Stage alarm. Action required.
- GS18 Attention, attention. Novec extinguishing system 2nd stage alarm. Extinguishing system release imminent. Please evacuate the area.
- GS19 Attention, attention. Novec extinguishing system hold-off device operated. Extinguishing system release on hold.
- GS20 Attention, attention. Novec extinguishing system has discharged. Do not enter.
- GS21 Novec extinguishing system 1st Stage alarm. Action required.
- GS22 Novec extinguishing system 2nd stage alarm. Extinguishing system release imminent. Please evacuate the area.
- GS23 Novec extinguishing system hold-off device operated. Extinguishing system release on hold.
- GS24 Novec extinguishing system has discharged. Do not enter.
- GS25 Attention, attention. Inergen extinguishing system 1st Stage alarm. Action required.
- GS26 Attention, attention. Inergen extinguishing system 2nd stage alarm. Extinguishing system release imminent. Please evacuate the area.
- GS27 Attention, attention. Inergen extinguishing system hold-off device operated. Extinguishing system release on hold.
- GS28 Attention, attention. Inergen extinguishing system has discharged. Do not enter.
- GS29 Inergen extinguishing system 1st Stage alarm. Action required.
- GS30 Inergen extinguishing system 2nd stage alarm. Extinguishing system release imminent. Please evacuate the area.
- GS31 Inergen extinguishing system hold-off device operated. Extinguishing system release on hold.
- GS32 Inergen extinguishing system has discharged. Do not enter.
- GS33 Attention, attention. Argonite extinguishing system 1st Stage alarm. Action required.
- GS34 Attention, attention. Argonite extinguishing system 2nd stage alarm. Extinguishing system release imminent. Please evacuate the area.
- GS35 Attention, attention. Argonite extinguishing system hold-off device operated. Extinguishing system release on hold.
- GS36 Attention, attention. Argonite extinguishing system has discharged. Do not enter.
- GS37 Argonite extinguishing system 1st Stage alarm. Action required.
- GS38 Argonite extinguishing system 2nd stage alarm. Extinguishing system release imminent. Please evacuate the area.

KLAXON - SONOS AND NEXUS VOICE SOUNDER MESSAGES

GAS / CHEMICAL RELEASE (Continued)

- GS39 Argonite extinguishing system hold-off device operated. Extinguishing system release on hold.
- GS40 Argonite extinguishing system has discharged. Do not enter.
- GS41 Attention, attention. Argotech extinguishing system 1st Stage alarm. Action required.
- GS42 Attention, attention. Argotech extinguishing system 2nd stage alarm. Extinguishing system release imminent. Please evacuate the area.
- GS43 Attention, attention. Argotech extinguishing system hold-off device operated. Extinguishing system release on hold.
- GS44 Attention, attention. Argonite extinguishing system has discharged. Do not enter.
- GS45 Argotech extinguishing system 1st Stage alarm. Action required.
- GS46 Argotech extinguishing system 2nd stage alarm. Extinguishing system release imminent. Please evacuate the area.
- GS47 Argotech extinguishing system hold-off device operated. Extinguishing system release on hold.
- GS48 Argotech extinguishing system has discharged. Do not enter.
- GS49 Attention, attention. Carbon dioxide extinguishing system 1st Stage alarm. Action required.
- GS50 Attention, attention. Carbon dioxide extinguishing system 2nd stage alarm. Extinguishing system release imminent. Please evacuate the area.
- GS51 Attention, attention. Carbon dioxide extinguishing system hold-off device operated. Extinguishing system release on hold.
- GS52 Attention, attention. Carbon dioxide extinguishing system has discharged. Do not enter.
- GS53 Carbon dioxide extinguishing system 1st Stage alarm. Action required.
- GS54 Carbon dioxide extinguishing system 2nd stage alarm. Extinguishing system release imminent. Please evacuate the area.
- GS55 Carbon dioxide extinguishing system hold-off device operated. Extinguishing system release on hold.
- GS56 Carbon dioxide extinguishing system has discharged. Do not enter.
- GS57 Attention, attention. Fire detector operated on the carbon dioxide system. Please evacuate and do not re-enter.
- GS58 Attention, attention. Carbon dioxide discharge imminent. Do not enter.
- GS59 Carbon dioxide released. Do not enter.
- GS60 Carbon dioxide system has discharged. Evacuate this area and do not re-enter as the air may contain a high level of carbon monoxide.
- GS61 A carbon dioxide system has discharged. Evacuate this corridor and do not re-enter as the air may contain a high level of carbon dioxide.
- GS62 Excessive carbon monoxide levels have been detected. Please leave the area immediately.
- GS63 Attention. Attention. Gas detected. Please evacuate the area.
- GS64 Acid spillage. Please evacuate immediately.
- GS65 Acid spillage. All Clear.
- GS66 Attention, .Acid spillage. Evacuate immediately.
- GS67 Attention. Corrosive gas leakage. Evacuate immediately.
- GS68 Attention. Chlorine gas leakage. Evacuate immediately.
- GS69 Attention. Poisonous gas leakage. Evacuate immediately.
- GS70 Attention. Toxic gas leakage. Evacuate immediately.
- GS71 Refrigerant gas detection alarm activated. Immediate action required.
- GS72 Humidity detection alarm activated. Immediate action required.
- GS73 High temperature detection alarm activated. Immediate action required.
- GS74 Overflow alarm activated. Immediate action required.
- GS75 Float alarm activated. Immediate action required.
- GS76 Attention! Attention! Please leave the room immediately. The oxygen level has dropped below the safe limit.

KLAXON - SONOS AND NEXUS VOICE SOUNDER MESSAGES

GAS / CHEMICAL RELEASE (Continued)

- GS77 Attention! Attention! Oxygen levels are now above the permitted levels. Immediate attention required.
- GS78 System is now in manual mode.
- GS79 System is now in automatic mode.
- GS80 Warning, low temperature. Please close all external doors.
- GS81 Warning, high temperature. Please open all external doors.
- GS82 Danger, low oxygen level. Evacuate the area.
- GS83 Warning. Argon alarm.

AIR SAMPLING / HSSD SYSTEMS

- AS1 Attention, attention there is an alarm in the Comms Room
- AS2 Attention, attention there is an alarm in the Computer Room
- AS3 Attention, attention the Vesda system has operated
- AS4 Attention, attention. The air sampling system has operated. First level alarm.
- AS5 Attention, attention. The air sampling system has operated. Second level alarm.
- AS6 Attention, attention. The air sampling system has operated. Third level alarm.
- AS7 Attention, attention. The air sampling system has operated. Fourth level alarm.
- AS8 Attention, attention. The air sampling system has operated. Action required.
- AS9 Attention, attention. The air sampling system has reached pre-alarm levels.
- AS10 Attention, attention. The air sampling system has operated. Fire.
- AS11 Attention, attention. The high sensitivity smoke detection system has operated. First level alarm.
- AS12 Attention, attention. The high sensitivity smoke detection system has operated. Second level alarm.
- AS13 Attention, attention. The high sensitivity smoke detection system has operated. Third level alarm.
- AS14 Attention, attention. The high sensitivity smoke detection system has operated. Fourth level alarm.
- AS15 Attention, attention. The high sensitivity smoke detection system has operated. Action required.
- AS16 Attention, attention. The high sensitivity smoke detection system has operated pre-alarm levels.
- AS17 Attention, attention. The high sensitivity smoke detection system has operated. Fire.
- AS18 Attention, attention. The air sampling system in the telecoms rooms has been activated. Action required.
- AS19 Attention, attention, the air sampling system in the data suite has been activated. Action required.
- AS20 Attention, attention. The air sampling system in the telecoms rooms has been activated.
- AS21 Attention, attention, the air sampling system in the data suite has been activated.

CONVEYOR MESSAGES

- CM1 Conveyor number one starting.
- CM2 Conveyor number two starting.
- CM3 Conveyor number three starting.
- CM4 Conveyor number four starting.

CLASS CHANGE

- CC1 This is a class change announcement.
- CC2 End of period.

KLAXON - SONOS AND NEXUS VOICE SOUNDER MESSAGES

GENERAL MESSAGES

- GN1 Warning, warning, gates are opening.
- GN2 Warning, warning, gates are closing.
- GN3 Warning this machine is being started.
- GN4 Warning, you are approaching a machine safety hazard, move away or the machine will shutdown.
- GN5 Warning, stand clear of all machinery. Warning, stand clear of all machinery.
- GN6 Attention. Attention. Hazardous area. Do not enter.
- GN7 Warning. Dangerous area. Do not enter.
- GN8 Danger. Danger. Do not enter.
- GN9 This is a hazardous area. Do not enter.
- GN10 This is a dangerous area. Do not enter.
- GN11 You are entering a hazardous area. Personal protective equipment should be worn.
- GN12 Caution. This gate is about to close.
- GN13 Caution. This gate is about to open.
- GN14 Warning! Track two starting in five minutes.
- GN15 Warning! Track two starting in two minutes.
- GN16 Warning! Track two starting.
- GN17 Fire shutter closure imminent. Please stand clear.
- GN18 Caution, train approaching.
- GN19 Caution there is a train approaching.
- GN20 Warning. Door activated. Stand clear!
- GN21 Warning. Fire door activated. Stand clear.
- GN22 Caution, door is about to operate.
- GN23 Danger. Fire curtain closing.
- GN24 Warning. Alarm system setting. Please escape to abort.
- GN25 Danger, molten metal.
- GN26 This is a no-smoking area. Please extinguish all smoking material.
- GN27 This is a no-smoking area. Please refrain from smoking, thank you.
- GN28 Attention! Attention! Would all managers report to the office.
- GN29 This site is private property. Please leave immediately.
- GN30 This is private property. You are under CCTV surveillance. Leave immediately.
- GN31 This site is private property. You are being recorded by CCTV cameras and the police have been contacted.
- GN32 This is a staff call, all managers to report to their offices.
- GN33 This is a call for staff assistance.
- GN34 This is a staff alert.
- GN35 Would designated personnel please carry out a security search.
- GN36 Please report back to your nearest supervisor.
- GN37 Intelligent safety system activated. Please stand clear.
- GN38 Isolation switch activated. This gate will not function normally.
- GN39 Emergency assistance required at poolside.
- GN40 This is a Security Alert. Please collect your belongings and leave the building.

KLAXON - SONOS AND NEXUS VOICE SOUNDER MESSAGES

GENERAL MESSAGES (Continued)

- GN41 Safety zone breach. Please move away from the machinery.
- GN42 Warning. Warning, You are approaching dangerous machinery.
- GN43 Foreign body detected.
- GN44 Machine shutdown.
- GN45 Safety has been breached. Shutting down.
- GN46 For your safety, please move away from the machine.
- GN47 This is a safety zone. Please move away from the machine.
- GN48 The machine is shutting down for your safety.
- GN49 Please stand away from the machinery.
- GN50 Stop.
- GN51 You are entering an unsafe area.
- GN52 Ringing Bell Sound
- GN53 Caution. Fork Truck working in area
- GN54 Alert. Trucks in area
- GN55 Be Alert. Trucks delivering materials
- GN56 Caution. Trucks delivering materials

SECURITY ALERTS / WARNINGS

- SA1 This is a security alert. Please leave the building by the nearest exit.
- SA2 There has been a security breach. Please leave the building as directed by staff.
- SA3 This is a security alert. Please leave the building as directed by staff.
- SA4 Intelligent safety system activated. Please stand clear.
- SA5 Isolation switch activated. This gate will not function normally.
- SA6 Please be aware that safety lighting will illuminate this area in thirty seconds.

MEDICAL ALERT

- MD1 This is a call for medical assistance.
- MD2 This is a medical alert.
- MD3 This hospital is now smoke free and smoking is not permitted anywhere in the building or within the hospital grounds. Thank you for your co-operation.

WATER ALARM

- WA1 Water detection alarm activated. Immediate attention required.
- WA2 Overflow alarm activated. Immediate action required.
- WA3 Float alarm activated. Immediate action required.